

Evidence of Performance

Energy efficiency and thermal insulation

Test report 432 29876/2e*

* Translation of Test Report 432 29876/2 dated 10 May 2005



Client **ALUMIL - MILONAS**
ALUMINIUM INDUSTRY S. A.
Industrial Area

61100 KILKIS
GREECE

Product	Fixed systems: Frame / transom Movable systems: sash-frame-transom combination
Designation	M 11500 ALUTHERM SUPER PLUS
Dimensions of cross section	Depth of frame / transom 76.5 mm Depth of sash 84 mm
Projected width:	Variable projected width
Material Surface	Thermal break aluminium profile, coated
Type and material of thermal break	Continuous polythermide bars, Polyamide 6.6 with 25 % glass fibre slightly oxidised surfaces, e.g. cavities following surface treatment by immersion
Special features	-/-

Basis


ift Guideline WA-01/1 (February 2002) „Verfahren zur Ermittlung von U_f -Werten für thermisch getrennte Metallprofile aus Fenstersystemen (Determination of the U_f -values of thermal break metal profiles used in window systems)
EN ISO 10077-2 : 2003-10 Calculation of thermal transmittance U_f Numerical method for frames.

Equivalent to the national versions DIN EN ISO as well as DIN EN.

Test report 432 29876/2 dated 10 May 2005

Representation

see Annex 1



Thermal transmittance



$$U_f = 1.9 - 2.1 \text{ W/(m}^2 \cdot \text{K)} *$$

- * The specified range of values refers to the profile combinations listed in tables 4 and 5 of this report. The U_f -values for additional profile combinations of the system are determined using the linear regression in accordance with table 6.



ift Rosenheim
08 May 2007

N. Sack

Norbert Sack, Dipl.-Phys.
Head of Testing Department for building physics
ift Centre Glass, Building Materials & Building Physics

Klaus Specht

Klaus Specht, Dipl.-Ing. (FH)
Test Engineer
ift Centre Glass, Building Materials and Building Physics

Instructions for use

This test report serves to demonstrate the thermal transmittance U_f of the tested profile system.

Validity

The data and results given refer solely to the described and tested specimen.

Testing the thermal transmittance does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

Contents

The report comprises a total of 12 page.

- 1 Object
- 2 Procedure
- 3 Detailed results
Annex 1 (4 pages)

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18
DAP-PL-0808 99
DAP-ZE-2298 00
TGA-ZM-16-93-00
TGA-ZM-16-93-00



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gielt-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00